

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211173
Address: 302 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Tuesday, May 17, 2022

Corrective Action Required:

1	Miscellaneous Correction	-WATER SERVICE INSPECTION STILL PENDING -OBTAIN LAWN IRRIGATION PERMIT & SUBMIT -BACK FLOW CERTIFICATION - SUBMIT AS GRADED PLOT PLAN -PROVIDE FINAL GRADE -PROVIDE SOD -PROVIDE SPLASH BLOCKS - COMPLETE STONE FRONT OF HOUSE - PROVIDE PERMANENT ADDRESS - REMOVE DUST COVERS SMOKE DETECTORS - PROVIDE FIXTURE OR COVER PLATE MASTER CLOSET - PROVIDE ANCHOR BOLT SCH 40 COLUMN AT SERVICE PANEL - COMPLETE EXHAUST HOOD KITCHEN -
---	-----------------------------	---

Comments: