

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210506
Address: 1713 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, May 17, 2022

Corrective Action Required:

1	Misc	-complete final grade and sod submit as graded plot plan -address pending sidewalk inspection -address siding from grade at concrete slabs -spark ring required above fireplace -outlet required at counter top in dining -to much trash in garage could not check outlets -top stair in basement not to code -security screws at back door to Lees summit security code
---	------	---

Comments: