



## STRUCTURAL STEEL OBSERVATION: K44912

**CLIENT:** STAR DEVELOPMENT CORP  
244 W MILL, STE 101  
LIBERTY, MO 64068

**REPORT NO:** K44912  
**REPORT DATE:** 2/28/2022  
**SERVICE DATE:** 2/8/2022

**PROJECT:** C20-21-170  
OAKVIEW LOTS 2-4

**AUTHORIZATION:**  
**CONTRACTOR:**

**SERVICES:** Structural Steel Observation

A deviation from KCTE's visit 1/04/2022 was observed to be repaired by the contractor. New bolts were installed of adequate length to fully engage the nut. This location is the beam to column connections. Also, KCTE observed the 1/4" fillet weld requirement from welds on angle to beam connections.

**TECHNICIAN:** JUSTIN CROOKS  
PROJECT MANAGER

**REPORT DISTRIBUTION:**  
AARON YOUNG  
CHRIS BROWN  
ADAM BROWN

KANSAS CITY TESTING & ENGINEERING, LLC,

---

SCOTT E. MARTENS, P.E.  
VICE PRESIDENT