

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215539
Address: 122 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, May 18, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Fasten top plate to header with 2 rows 16d sinkers at 3" OC per plan-PFH per plans nailed in garage portal circled detail in red ink
---	--------------------------	--

Comments: