

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215415
Address: 2122 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, May 18, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide H2.5a front porch PFH portal framing Solid block sheathing break single car garage Fasten top plate to header with two rows 16d sinkers at 3" OC per fplan 5/8 anchor bolts in middle third width of plate with square washers Connect bath exhaust with metallic tape water closet bed 1 Provide 2x6 continuous stud wall full height covered porch per plan
---	--------------------------	--

Comments: