

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213473
Address: 310 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Wednesday, May 18, 2022

Informational:	
1 Misc	RETAIL SPACE ONLY APPROVED FOR OCCUPANCY
Corrective Action Required:	
2 Miscellaneous Correction	Upload health dept inspection to permit on city portal Provide hammer arrestors washing machine Exit sign in brewery test button upside down Anti siphon device at mop sink Ok to Stock & Train

Comments: