

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220752

Address: 1980 SE BLUE PKWY, Unit:2302, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Robb Popp	Not Ready	Wednesday, May 18, 2022

Corrective Action Required:

1	Misc	-Missing bonding screw and jumper at metallic cut in box in stairwell wall-5/18/22 still no corrections made
---	------	--

**Comments:**