

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220073
Address: 3534 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, May 18, 2022

Corrective Action Required:

1	Misc	-MIN 36" PIER DEPTH FOR FROST DEPTH -MIN 18" WIDE PIERS PER PLANS, ENSURE 18" MIN CONT PIER, PIERS BELLED
---	------	--

Comments: