

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20212476
Address: 3200 SW ARBORTREE DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Mitchell Schwarz	Failed - Stop Work	Wednesday, May 18, 2022

Corrective Action Required

1	DCM3 ESC REQUIRED 2 DAY	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	-------------------------	--

Corrective Action Required

2	Misc	drive way and sidewalks just poured erosion control to be in compliance within 2 business days.
---	------	---

Corrective Action Required

3	Misc	Erosion control still not in compliance -Side of lot -"outdoor restroom" in street
---	------	--

Comments: