

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215294  
Address: 2104 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, May 18, 2022

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- complete patio roofing to lvl per engineer letter</li><li>-furr out of dwv and pex In Kitchen and (fireblock)</li><li>-address ledger to beam connection above kitchen/dining also nail all hangers</li><li>-address great room windows not framed to plans</li><li>-complete bath vent install at master bath</li><li>-complete framing at front stoop and support ridge beam</li><li>-complete bath vent in 2nd story baths</li><li>-connect ufer to middle grounded bus bar</li><li>-provide pressure gauge at gas for inspection minimum 10psi</li></ul>
---	------	--

**Comments:**