

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215181
Address: 2034 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Wednesday, May 18, 2022

Corrective Action Required:

1	Misc	-missing nuts on anchors in garage (could not inspect) -install all windows and doors -complete stairs at garage and fire block -complete bath fans at master -complete bath fan in jack and Jill bath
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: