CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212125

Address: 144 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Wednesday, May 18,

Residential 2022

Corrective Action Required:

1 Miscellaneous - obtain an irrigation permitCorrection - Submit a back flow certification

- Back flow preventer in basement and inspected (fyi)

- Seal penetration at gas meter

- Seal top of meter and A/C disconnect

- Label non GFCI outlet in garage

- Install back flow device at water main

- R507.1(1) 1/2" through bolts required at post to beam connections

Comments: