


May 16, 2022

Clover & Hive
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue of multiple holes in rim joist for Lot #155 Cobey Creek – 3538 SE Corbin Dr. Lee's Summit, MO 64082 – Permit # PRRES20220006



- D1 – varies
- D2 – varies
- Diameter of hole – 1"
- Length 1 – varies
- Length 2 – varies
- Span – 16" rim joist
- Location – between floor joists above rear coat closet

Recommended modifications:

- Install 2x10 solid blocking in adjacent floor joist bay.

Sincerely,



Bradley Huxol, PE

