

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20210623  
Address: 2118 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Thursday, May 19, 2022

Informational:

1	5/5-NOT READY FEE ASSESSED.
---	-----------------------------

Corrective Action Required:

2	Miscellaneous Correction	Pay not ready fees Seal top exterior light fixtures Provide clamp on ac whip AC max breaker 30 amp has 40 installed Lower Water meter pit lid to grade No covered patio pier inspection plan show (2) 16x36 piers
---	--------------------------	--

Comments: