

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213320
Address: 3121 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, May 19, 2022

Corrective Action Required:

1	Misc	- sod -seal all exterior penetrations -un cover water meter for inspection -submit as graded plot plan -address to be of contrasting colors -seal top of -guard rail as required by code at front stoop -security screws at back door -seal underneath furr out wall in garage -attic access cover -outlet at A/c not working -
---	------	--

Comments: