

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210293
Address: 3022 NW THOREAU PL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, May 19, 2022

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none">- pay all fees- Final grading and sod- irrigation permit and back flow certification if irrigation is installed- Splash blocks- Label all non GFCI outlets- Spindles missing- Nail hangers on deck- Piers and post on deck stairs- Address down spout by deck stairs- security lights- Security screws in front door
---	--------------------------	--

Comments: