

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215616  
Address: 2103 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Not Ready	Thursday, May 19, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Provide stud shoe washing machine drain-USE MANUFACTURER REQUIRED FASTENERS -Tighten anchor bolt basement near line set-NOT DONE
---	--------------------------	--

**Comments:**