

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20213070  
Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, May 19, 2022

Corrective Action Required:

1	Misc	-Frame CSPF walls per plan **Your engineered plan shows the CSPF walls per A/4 detail at rear master bedroom and dining room. You can get back with your engineer to revised the plan or submit letter for omission of the CSPF walls
---	------	---

\*\*OK TO INSULATE

\*\*UFER grounding connection must be accessible at final

**Comments:**