

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212569  
Address: 2353 SW HICKORY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection - R</b>	Mitchell Schwarz	Failed	Thursday, May 19, 2022

Corrective Action Required:

2	Misc	-Meter be 14"-18" from top of meter to pit ring and lid -copper must extend 10' out of meter well before switching to pex
---	------	--

Comments: