



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100205, Building Permit - Commercial
Address: 350 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Passed	Friday, January 07, 2011

Comments: OK TO POUR WHEN READY: TWO OUTER CANOPY FOOTINGS; TWO INNER CANOPY FOOTINGS WITH RE-BAR DOWELED INTO EXISTING WALL FOOTING (ONE ADDITIONAL MAT INSTALLED TO SUPPLEMENT DESIGNED STRENGTH).