

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSITE20221062

Address: 904 NW PRYOR RD, LEES SUMMIT, MO 64081908 NW PRYOR RD, LEES SUMMIT, MO 64081900  
NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	Michael Harkins	Partial	Thursday, May 19, 2022

Informational:

1 Misc

9 of 11 light pole bases

6' #8 Coiled copper in base per plan  
No driven ground rod at this time #8 copper  
needs to be clamped to ground rod

2 at rear of lot in front of 940 Pryor  
1 at fire hydrant south side  
1 SE near inlet  
2 at front of middle bldg pad  
1 at rear middle pad  
1 at NW corner of lot  
1 south of north bldg pad

**Comments:**