CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213384

Address: 301 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Friday, May 20, 2022

Residential

Corrective Action Required:

1 Miscellaneous - provide sodCorrection - Splash blocks

- Sump discharge minimum of 36"

- Remove dust covering from smoke detectors (non tested)

Provide secondary lock on sliding doorSecurity screws required in exterior doors

Comments: