

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213997

Address: 605 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081
605 NW REDBUD DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Friday, May 20, 2022

Corrective Action Required:

1	Misc	UNIT A 1ST LAYER 5/8 TYPE X SCREW PATTERN WALLS & RAFTERS APPROVED : NEED TO CHECK SCREW PATTERN GB METHOD AT LIBs WITH 2ND LAYER UNIT B 1ST LAYER 5/8 TYPE X SCREW PATTERN WALLS & RAFTERS APPROVED : NEED TO CHECK SCREW PATTERN ON GB METHOD AT LIBs WITH 2ND LAYER
---	------	---

Comments: