

DEVELOPMENT SERVICES

Residential Plan Review

May 20, 2022

Ecovole
1444 grand blvd ste 1202
kansas city, MO 64106
(816) 351-7803

Permit No: PRRES20222063
Plan Name:
Project Address: 129 NW MACKENZIE DR, LEES SUMMIT, MO 64081
Parcel Number: 62330040500000000
Location: WINTERSET VALLEY 12TH PLAT LOTS 1435 THRU 1471 & TRACTS A12 THRU D12---LOT 1463
Type of Work: ALTERATION SINGLE FAMILY
Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY
Description: ROOF MOUNTED SOLAR - 14.19 KW

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Plot Plan Review	Reviewed By: Joe Frogge	Not Required
Residential Plan Review	Reviewed By: Joe Frogge	Rejected

1. System exceeds 15KW.

Action required: Designs must be sealed/signed by Electrical Engineer.

Fire Department Solar Review	Reviewed By: Jim Eden	Rejected
-------------------------------------	------------------------------	-----------------

1. Provide PE stamped plans.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:			
Roofing Material		Number of Bathrooms	

Number of Bedrooms		Number of Stories	
Number of Living Units		Total Living Area	