

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215494  
Address: 2130 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, May 20, 2022

Corrective Action Required:

1	Misc	-fireblock hvac chase at great room windows to furr down and ceiling above [near fire place] -seal gap into furr down in garage from dining room -provide 30" head clearance at attic access -missing steel column at stairwell -nail exterior sheathing to plans/code
---	------	--

**Comments:**