

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214081

Address: 2009 SW OSAGE DR, LEES SUMMIT, MO 64082 2011 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|--------------------|----------|----------------------|
| Rated Assembly Inspection | Patrick Schonfeldt | Failed | Friday, May 20, 2022 |

Corrective Action Required:

1 Misc

UNIT 2009

- Missing "C channel at fire rock roof deck, have engineer address repairs to UL design submitted, sheet metal faced nailed to rock
- Address damaged fire rock
- Fire rock not seated in H track
- Fire rated partition required at basement foundation rear corner per plan, per approved UL design

UNIT 2011

- Missing "C channel at fire rock roof deck, have engineer address repairs to UL design submitted, sheet metal faced nailed to rock, fire caulk painted of fire rock for repair
- Address damaged fire rock
- Fire rock not seated in H track
- No vents allowed in first 4' of firewall at fire rated plywood
- Fire rated partition required at basement foundation rear corner per plan, per approved UL design

Comments: