



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100052, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:I, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Alarm Test	Joe Dir	Passed	Friday, January 07, 2011
Occupancy Inspection - Fire	Joe Dir	Passed	Friday, January 07, 2011
Final Building Inspection - Commercial	John Borns	Passed	Friday, January 07, 2011

Comments: ENSURE THAT ELECTRICAL AND GAS SERVICES FOR SUITES I AND J ARE CORRECTLY LABELED AT POINTS OF SERVICE.