

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214475  
Address: 205 NW JOSHUA DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Shawn Hoffman	Failed	Monday, May 23, 2022

Corrective Action Required:

1	Misc	-GAS PRESSURE 5 PSI, MUST MAINTAIN 10 PSI FOR TEST ( 5/18/22 0 psi not ready )
---	------	---

Shawn Hoffman 05/23/2022 8:56 AM ONLY 6 LB

**Comments:**