

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212005
Address: 516 SE CARTER RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, May 23, 2022

Corrective Action Required:

1 Misc

-address hips landing on blocks, amount of taper cut for hips from 2x10
hip,address hip and dbl joist notched master bath
Have engineer address field fix for hips

****OK TO INSULATE****

Comments: