

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213997

Address: 605 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081605 NW REDBUD DR, Unit:A, LEES  
SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Partial	Monday, May 23, 2022

Corrective Action Required:

1	Misc	UNIT A 1ST LAYER 5/8 TYPE X SCREW PATTERN WALLS & RAFTERS APPROVED UNIT A 2ND LAYER 5/8 TYPE X SCREW PATTERN & FIRE CAULK  : NEED TO CHECK SCREW PATTERN GB METHOD AT LIBs WITH 2ND LAYER  UNIT B 1ST LAYER 5/8 TYPE X SCREW PATTERN WALLS & RAFTERS APPROVED UNIT B 2ND LAYER 5/8 TYPE X SCREW PATTERN & FIRE CAULK  : NEED TO CHECK SCREW PATTERN ON GB METHOD AT LIBs WITH 2ND LAYER
---	------	---

Comments: