

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215300
Address: 500 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-----------------|----------|----------------------|
| Rough Framing Inspection - Commercial | Michael Harkins | Failed | Monday, May 23, 2022 |

Corrective Action Required:
2 Miscellaneous WALK UP CANOPY
 Correction COMPLETE LEDGER LOCK SCREWS SOUTH END
 DOUBLE JOIST HANGERS ARE UPSIDE DOWN NORTH & SOUTH ENDS

Comments: