

# LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS  
207 SE DOUGLAS STREET  
LEE'S SUMMIT, MISSOURI 64063-2372  
(816) 969-1300  
FAX (816) 969-1313  
TDD (816) 969-7407

## PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100041	Date:	January 11, 2011
Project Title:	Progressive Insurance	Applicant:	
Location:	400 SW LONGVIEW BLVD, Unit:125, LEES SUMMIT, MO 64081		System Integration Group 6600 Royal St. Bldg B (816) 415-0203
Type of Work:	Alarm Alteration		
Occupancy Group:	B		
Construction Type:	Type IIB (Unprotected)		
Map Page:	194E		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

### **Alarm Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Alteration shop drawings received 1/10/2011.

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule testing.

3. All appliances shall be compatible with existing equipment.

.