

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216495  
Address: 101 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector:    | Outcome: | Date:                 |
|--------------------------------------|---------------|----------|-----------------------|
| <b>Electrical Service Inspection</b> | Shawn Hoffman | Failed   | Tuesday, May 24, 2022 |

Corrective Action Required:

|   |                             |   |
|---|-----------------------------|---|
| 1 | Miscellaneous<br>Correction | Not bonded to UFER<br>Provide #4 jumper from grounding bus to neutral bus |
|---|-----------------------------|---|

**Comments:**