

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211043
Address: 1426 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Tuesday, May 24, 2022

Corrective Action Required:

1	Misc	Tempered glazing required at windows master bath jacuzzi tub Tempered glazing required at 2nd floor stairs landing Provide gravel at water meter pit Final sidewalk inspection required, contact development services to schedule resolve outstanding inspection fees
---	------	---

Comments: