



May 24, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Clarification of engineered bracing for Lot #85 Hawthorne Ridge –1519 Arbor Valley Lee's Summit, MO 64082 – Permit # PRRES20213629

- LP Panel siding – 7/16" grooved shall be equivalent to 3/8" thick OSB.
- OSB may be omitted underneath 7/16" grooved panel siding in areas requiring 3/8" thick OSB.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a faint, larger version of the same signature.

Bradley Huxol, PE

