

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214505
Address: 3238 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Tuesday, May 24, 2022

Corrective Action Required:

1	Misc	repair silt fence
---	------	-------------------

Corrective Action Required:

2	Misc	Silt fence on SW corner of property at Gale Dr/Sw Pergola park is not functioning, mud and silt are flowing underneath and have enveloped the ADA ramp at this location. Please correct. 5/24/22 ES
---	------	---

Comments: