

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212068
Address: 3213 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Tuesday, May 24, 2022

Corrective Action Required:
2 Misc Silt fence needs repaired around property, but especially in back where draining into alley way. 5/24/22 ES

Comments: