

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210742  
Address: 1518 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Robb Popp	Failed	Wednesday, May 25, 2022

Corrective Action Required:

1	Miscellaneous Correction	-IDENTIFY UFER GROUND AT EACH END -PROVIDE PROPER LISTED CLAMP AT UFER CONNECTION -REMOVE BONDING JUMPER IN SUB PANEL- ISOLATE GROUND AND NEUTRAL BARS
---	-----------------------------	--

**Comments:**