

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210742
Address: 1518 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Robb Popp	Failed	Wednesday, May 25, 2022

Corrective Action Required:

1	Misc	-COMPLETE GAS CONNECTION TO FIREPLACE -IDENTIFY METALLIC GAS LINE BONDING CONDUCTOR AT EACH END
---	------	--

Comments: