

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214075  
Address: 3117 SW ARBORTREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:       | Outcome: | Date:                   |
|---------------------------------------------|------------------|----------|-------------------------|
| <b>Gas Service Inspection - Residential</b> | Mitchell Schwarz | Failed   | Wednesday, May 25, 2022 |

Corrective Action Required:

|   |      |                                                                                                |
|---|------|------------------------------------------------------------------------------------------------|
| 2 | Misc | -No pressure at gas gauge for inspection<br>-provide minimum 10psi at gas gauge for inspection |
|---|------|------------------------------------------------------------------------------------------------|

**Comments:**