

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20214075  
Address: 3117 SW ARBORTREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, May 25, 2022

Corrective Action Required:

2	Misc	-attic access in garage -fire blocking at furr outs in garage (if using Unfaced insulation must be packed tight and secured) -address over board joist above garage entry -address broken joist above great room /foyer at lvl connection -complete bath fan we entry bath -hangers missing at front porch -provide all hangers and nail off in 2nd story -seal top plate penetration bed 2 -install truss hold down screws in multiple areas missing and improperly installed -address dryer vent length -address Over notched floor joist at furnace for hvac line set
---	------	--

**Comments:**