

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213953
Address: 1517 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, May 25, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- address over bored stud at garage SEC cable- Fire block penetration top plate garage at electrical panel- Tighten anchor bolts garage- Fire block penetration top plate garage low voltage- Relocate LIB in laundry- Boca plate at ice maker- Seal penetration fire place gas line- Nail 4 pack bedroom 1 exterior wall- Repair floor bathroom 1- Fire block penetration at master shower- Fire block floor at master tub- Fire block penetration bedroom 2 tub- Fire block plenum space at RA bedroom 3 basement- Add middle support for soffit basement by mechanical over 4'- Provide steel columns in basement mechanical room |
|---|--------------------------|--|

Comments: