

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215425
Address: 2031 SW WHEATFIELD CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, May 25, 2022

Corrective Action Required:

2	Misc	-Obtain lawn irrigation permit -GFCI protection required at laundry -spark rings as required at kitchen outlets -open neutral at outlet under kitchen sink -outlet required at kitchen island to code -security screws at back doors -spark ring required above kitchen fire place -outlet in down stairs bath not working -labeled breaker panel for inspection make sure all breakers requiring a lock out have one -secure A/c whip within 12" of disconnect -tamper resistant caps at a/c unit -seal top of meter can, A/c disconnect and all other exterior penetrations
---	------	--

Comments: