



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100041, Building Permit - Commercial
Address: 400 SW LONGVIEW BLVD, Unit:125, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Partial	Friday, January 14, 2011

Corrective Action Required
1 MISC

TAPE AND INSULATE DUCT OVER DATA ROOM.
DUCT WEST OF DATA ROOM AT HVAC UNIT
OK TO INSTALL CEILING TILE
LEAVE AREAS OPEN FOR INSPECTION ON THE ABOVE ITEMS

Comments: