

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221121
Address: 1237 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Not Ready	Thursday, May 26, 2022

Corrective Action Required:

1	Miscellaneous Correction	Vertical fire blocking every 10' Fire block vertical to horizontal at HVAC chase Provide blocking for 18 vertical grab bar restroom
---	-----------------------------	---

Comments: