

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213399
Address: 2938 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, May 26, 2022

Corrective Action Required:

1	Misc	-set screw in place and sheared off at water anti syphon device -submit as graded plot plan -sod -check water meater at time of sod -splash blocks and sump pump discharge to extend 36" from foundation
---	------	--

Comments: