

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213954

Address: 2015 SW OSAGE DR, LEES SUMMIT, MO 64082 2017 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Thursday, May 26, 2022

Corrective Action Required:

1	Misc	UNIT 2015: -gray caulking on firewall does not meet ASTM E814, UL 1479 rating
		UNIT 2017: -gray caulking on firewall does not meet ASTM E814, UL 1479 rating

Comments: