

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215970
Address: 4544 NE SENECA TER, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, May 27, 2022

Corrective Action Required:

1	Misc	-Feeder ampacity shall be de-rated for temperature in attic **protect SE cable at wall plate **I need the load calculation for the 100 amp sub panel -Install fireplace flue insulation shield **What happened to the fireplace? -Seal penetrations of joist return air space **in basement
---	------	---

Comments: