



VAN DEURZEN AND ASSOCIATES, P.A.
CONSULTING STRUCTURAL ENGINEERS
11011 KING STREET, SUITE 130
COMMERCE TERRACE BUILDING D
OVERLAND PARK, KANSAS 66210
(913) 451 - 6305 FAX (913) 451 - 1021

May 26, 2022

City of Lee's Summit
Division of Inspections
220 S.E. Green
Lee's Summit, MO 64063

Re: Osage Clubhouse Light Pole Base – Foundation Evaluation Report
2025 SW 150 HWY
Lee's Summit, MO

Dear Division of Inspections,

This letter is in regard to our evaluation of the two light pole bases located in the parking lot of the above mentioned address. We understand that the concrete bases for the light poles were installed without city inspection and approval. Our evaluation consisted of reviewing photographs taken of the bases prior to the placement of concrete.

Based on the photographs reviewed by our office, the reinforcement in the bases appeared to have been installed in general conformance with the permit drawings along with the required grounding rod. In addition, the depth and diameter of the bases appeared to be in conformance with the permit drawings.

Based on our evaluation of the installed light pole bases, we certify that the base diameter, depth and reinforcement have been installed in general conformance with the permit drawings.

We trust this information will meet your needs. If you need any additional information, please contact this office.

Sincerely,

VAN DEURZEN AND ASSOCIATES, P.A.

Chad M. Streeter, P.E.



5/26/2022