

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212838
Address: 528 SE DAVID RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, May 27, 2022

Corrective Action Required:

1	Misc	-submit as graded plot plans for review and approval -final sidewalk inspection required, contact development services to schedule -final grade and sod -gutters and downspouts -splash blocks -cover plates at kitchen outlets -GFCI protection required at dishwasher receptacle -install light fixture under stairs at sump pump or cover box -wet bar dishwasher requires GFCI protection
---	------	---

Comments: